

NEIL ABERCROMBIE  
GOVERNOR OF HAWAII



LINDA ROSEN, M.D., M.P.H.  
DIRECTOR OF HEALTH

STATE OF HAWAII  
DEPARTMENT OF HEALTH  
P. O. BOX 3378  
HONOLULU, HI 96801-3378

In reply, please refer to:  
File:

Hawaii Dairy Mgmt final ltr.

September 15, 2014

RECEIVED

Mr. Paul T. Matsuda, P.E.  
Group 70 International  
925 Bethel Street, 5<sup>th</sup> Floor  
Honolulu, Hawaii 96813-4307

SEP 18 2014

Dear Mr. Matsuda:

GROUP 70 INTL

Subject: **Hawaii Dairy Farm (HDF)  
Waste Management Plan (WMP)  
Mahaulepu, Kauai, Hawaii  
TMK: (4) 2-9-003:001 por and 006 por & (4) 2-9-001:001 por**

Thank you for your responses to the Department of Health, Wastewater Branch's (DOH-WWB) questions dated June 3, 2014 for the subject WMP. DOH-WWB has reviewed HDF's building facilities plan for Phase One only. Based on that review, the DOH-WWB does not object to the issuance of a building permit. DOH-WWB is not approving or taking any other action at this time on HDF's overall WMP.

Please be informed that DOH's sign-off on the building permit is also contingent on the DOH Sanitation Branch's review of the HDF's plans. As of today, the DOH Sanitation Branch is still reviewing the plans for HDF and has not given their approval to sign-off on the building permit. Should you have any questions about the status of this review process, please contact the Sanitation Branch at 586-8000.

In prior meetings, HDF agreed to take baseline water quality data of the Waiopili Stream. DOH-WWB requests that HDF provides the following data:

Establish baseline water quality data for the Waiopili Stream. The water should be tested for nutrients (nitrate, nitrite, ammonia, total phosphate and total nitrogen), e.coli, enterococci and clostridium. A minimum of one sample should be taken 50 feet upstream of the dairy, adjacent to the dairy at mid-point of the dairy property and 50 feet downstream of the dairy property. The sampling results should be submitted to DOH-WWB by November 30, 2014.

Should you have any questions or concerns, please feel free to contact me at (808) 586-4294.

Sincerely,

A handwritten signature in black ink, appearing to read "Sina Pruder", is written over a horizontal line.

SINA PRUDER, P.E., CHIEF  
Wastewater Branch

SP:lmj